

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7170-0028:204 Page 1 of 2

CATEGORY: Control Unit (High-Rise)

LISTEE: Notifier, A Pittway Company, One Fire-Lite Place, Northford CT 06472-1653
Contact: Larry Flood (203) 484-1200

DESIGN: Model AFC-600 fire alarm control unit. Local, auxiliary, remote station (PPU), proprietary (PPU), central station (PPU), waterflow and sprinkler supervisory services. Refer to listee's data sheet for detailed product description and operational considerations. System components:

CPU-600	CPU Board
MPS-6	Power Supply Board
CAB-600AA, -A3, -B3, -C3, -D3	Enclosure
4XTM	Transmitter
UDACT	Universal DACT
BB-17, -55	Battery Box
AMG-1, -E	Audio Message Generator
ARM-4	Auxiliary Relay Module
ATG-2	Audio Tone Generator
CRE-4	Control Relay Expander Module
CRM-4	Control Relay Module
DCM-4	Dual Channel Module
FFT-7, -7S	Fire Fighter Telephone
FHS	Fireman's handset
FPJ	Fireman's Phone Jack
ICM-4	Indicating Circuit Module
ICE-4	Indicating Circuit Expander Module
MMX-1, -101	Monitor Module
NIB-96	Network Interface Board
RPJ-1	Remote Phone Jack
UZC-256	Universal Zone Coder
VCE-4	Voice Control Expander Module
VCM-4	Voice Control Module
A2143-00, A2143-10	EOL Resistor
AA-30, -100, -120	Audio Amplifier
ACT-1	Audio Coupling Generator
BM-1	Blank Module
BP-3	Battery Dress Panel

02-07-2000

CCM-1	Communication Converter Module
CHS-4, -4L, -6	Chassis
DP-1, -400, -600AA, DPDW, DPSW-1	Dress Panel
ISO-X	Loop Isolator Module
MPS-6	Power Supply Module
STS-1, -200	Tamper Switch
TR-3 Series	Trim Ring
VS4095	Keltron 40 Column Printer
WC	Wire Channel
XPC-8	Transponder Control Module
XPDP	Transponder Dress Panel
XPP-1	Transponder Processor
XPR-8	Transponder Relay Module
XPM-8, -8L	Transponder Monitor Modules

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units suitable for high rise applications for use with separately listed compatible initiating and indicating devices.

This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 1996 Edition. Refer to listee's **Installation Instructions Manual** for details.

NOTE: For **Fire Alarm Verification** feature (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

02-07-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 7, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**